

# TATA CONSULTING ENGINEERS LIMITED

<b>ACCEPTANCE NOTE AND SHIPPING RELEASE</b>		REF. TCE. 6328A-EL-SR-06	DATE: 04-07-2012
CLIENT	CORNING TECHNOLOGIES INDIA (P) LTD.	FOLLOWING ITEMS ARE ACCEPTED & CLEARED FOR DESPATCH/VENDOR SHALL OBTAIN DESPATCH CLEARANCE FROM CLIENT/TCE PROJECT MANAGER	
PROJECT	GREENFIELD PROJECT, CHAKAN		
PO REF.			
MAIN VENDOR	Sterling and Wilson	INSP. REPORT TCE. 6328A-EL-06	DATE 04-07-2012
MAIN ITEM	Lighting panels	IDENTIFICATION STAMP BY TCE	
SUB-VENDOR	Samcon Industrial controls Pvt. Ltd.	LOCATION	QTY. STAMP
PO DELIVERY DATE	-	-	-
MAIN/SUB-ORDER COMPLETION	PARTIAL/COMPLETE		


SL. NO.	PO/BOM ITEM NO.	ITEM DESCRIPTION	QTY. REQD.	QTY. ACPTD.		INSP. CODE	REMARKS SL. NO., TAG NO., ETC.
				NOW	TOTAL		
1		Lighting panel -3 (12way)	01	01	01	1,2,4,8 ,15,16	P.O No. 4200139491/25104/12
2		Lighting panel -4 (12way)	01	01	01		
3		Lighting panel -5 (12way)	01	01	01		
4		Lighting panel -6 (12way)	01	01	01		
5		Lighting panel -7 (12way)	01	01	01		
6		Lighting panel -6 (8way)	01	01	01		
7		Street Lighting Panel	01	01	01		

INSP. CODE	1	VISUAL	6	STATIC/DYNAMIC BALANCE	10	DEFLECTION TEST	15	ROUTINE TESTS
	2	DIMENSIONS	7	AIR/HYDRO. LEAK TEST	11	CALIBRATION	16	REVIEW VENDOR'S INSP/ TEST REPORT/ CERTIFICATE
	3	MATERIAL IDENTIFICATION	8	OPERATION	12	LINING TESTS		
	4	REVIEW OF M.T.C.	9	PERFORMANCE AT NO LOAD/ PART/FULL/OVER LOAD	13	COATING TESTS		
	5	STAGE INSPECTIONS			14	TYPE TESTS		

**NOTES**

- Acceptance/release of the above items is without prejudice to the terms and conditions of the contract and does not relieve the vendor of his guarantees and responsibilities to supply the items in accordance with the specifications, approved drawings, data sheets and other relevant contract documents/conditions.
- Vendor shall comply with the packing and dispatch instructions and documentation requirements given below.
- For items supplied by sub-vendors, dispatch clearance shall be given to them by the main Vendor after ensuring that the items are satisfactory as per the technical and contractual requirements and after obtaining Shipping release/Acceptance note from TCE and/or dispatch clearance from TCE's client.

PACKING AND DISPATCH INSTRUCTIONS			SUBMIT FOLLOWING TO CLIENT/TCE			
1	Complete assembly with drive, base plate, accessories etc.		1	Quality doc. package	6	As built drawings
2	Protect machined surfaces against corrosion.		2	Erection, O&M manual	7	Calibration reports
3	Blank nozzles and other openings.		3	TC for performance/ leak tightness/balancing		
4	Complete painting, affix name plates, tag no., sl. no., etc.		4	Performance calculations, curves.		
5	Pack to prevent damage/deterioration in handling, transit & storage.		5	Guarantee certificates	8	Dispatch details
6	Paint dispatch markings and weight.					

COMPLETE FOLLOWING SHORT SUPPLY	CARRY OUT FOLLOWING RECTIFICATIONS	SEE REMARKS GIVEN BELOW
1. Complete the street lighting panel with respect to wiring and component fixing		1. Test certificates of bought out items, routine test, type test certificate with panel as built drawings shall be provided at the time of dispatch. 2. Manuals for all equipments shall be submitted with panel.
SIGN. 	NAME S.V. Padegaonkar	DESIGNATION P.E